



SECTION A-A

**NOTES:**

1. CONCRETE ENGAGEMENT DETAILS SHALL APPLY WHERE A WATERLINE CROSSES AN EXISTING OR PROPOSED SEWER WITH LESS THAN 18" VERTICAL OR 10' HORIZONTAL SEPARATION. NO CONCRETE ENGAGEMENT SHALL BE REQUIRED WHEN 18" OR MORE VERTICAL OR 10' HORIZONTAL SEPARATION IS PROVIDED BETWEEN THE WATERLINE AND SEWER.
2. SEWER MAY BE CONSTRUCTED TO WATERLINE PIPE STANDARDS AS AN ALTERNATE TO CONCRETE ENGAGEMENT OF WATER MAIN.

**WATERLINE ENGAGEMENT DETAIL**

CITY OF BOWLING GREEN PUBLIC WORKS DEPARTMENT ENGINEERING DIVISION		STD DWG 9
		SH 1 OF 1
		REV 10/2008