



INSIDE SERVICE CONNECTION (FOR METERS 5/8" x 3/4", UP TO 1")

METER NOTES:

1. NO VALVE SHALL BE INSTALLED BETWEEN CURB BOX AND METER SETTING.
2. 1 1/2" AND 2" METER VALVES SHALL BE GATE VALVES OR BALL TYPE.
3. 3" METERS AND LARGER REQUIRE RW GATE VALVES.
4. BACKFLOW PREVENTION DEVICE REQUIRED IMMEDIATELY FOLLOWING METER VALVE. TESTABLE DEVICE SHALL BE INSTALLED FOR COMMERCIAL PROPERTIES.
5. METERS LARGER THAN 1" ARE INSTALLED USING FLANGES.
6. VALVES AND YOKE ARE AVAILABLE FROM THE CITY OF BOWLING GREEN - DEPARTMENT OF WATER AND SEWER
7. METER SHALL BE INSTALLED IN ACCESSIBLE LOCATION APPROVED BY WATER DIVISION.
8. INSTALL METER MINIMUM 12 INCHES FROM WALL.

WATER SERVICE & METER DETAIL

CITY OF BOWLING GREEN PUBLIC WORKS DEPARTMENT ENGINEERING DIVISION	STD DWG 16
	SH 1 OF 1
	REV 03/2019